

From: [Brian Moore](#)
To: [Zehner, Warren](#); [Abshire, David](#)
Cc: [Bob Piniewski](#)
Subject: Malone EPA ER Week 13 Summary
Date: Monday, October 05, 2015 3:47:38 PM
Attachments: [Malone-Injection Well Summary Table-Week 13.pdf](#)

Dear Warren and David,

Below please find a general weekly update discussing Injection under EPA ER at the Malone Service Superfund Site in Texas City, TX. Attached please find the injection summary.

Monday 9/28/15- WDW-138: Contact water injection during working hours, WDW-73: Contact water injection during working hours

Tuesday 9/29/15- WDW-138: Contact water injection during working hours until Electrical issues shut well down, order new 150 HP motor WDW-73: Contact water injection during working hours

Wednesday 9/30/15- WDW-138: No injection, electrical issues, Electricians on-site to troubleshoot, appears we have a bad transformer which destroyed the 150 HP electric injection pump motor.
WDW-73: Contact water injection during working hours

Thursday 10/1/15- WDW-138 No injection due to electrical issues, order used transformer . WDW-73: Contact water injection during working hours.

Friday 10/2/15- WDW-138: No injection due to electrical issues. WDW-73: Contact water injection during working hours.

Saturday 10/3/15- WDW-138 No injection due to electrical issues, Electricians replace transformer but power provider needs to check incoming power on Monday. WDW-73: No injection due to electrical issues due to workers day off

Sunday 10/4/15- WDW-138: No injection due to electrical issues. WDW-73: No injection due to workers day off.

Should you have any questions please let me know.

Kindest Regards,

Brian Moore

Construction Manager

Malone Service Superfund Site RD/RA

Project Navigator, Ltd.

10497 Town & Country Way, Suite 830



9716109

Houston, TX 77024
Direct: 713.468.5961
Cell: 713.534.4546
Fax: 713.468.4515

E-MAIL NOTICE; This transmission may be (1) subject to Attorney-Client Privilege, (2) an attorney work product, or (3) strictly confidential. If you are not the intended recipient of this message, you may not disclose, print, copy or disseminate this information. If you have received this in error, please notify the sender only and delete the message.